SIEMENS

Data sheet 6EP1935-6ME21



SITOP Battery module/24V/7AH

SITOP battery module 24 V/7 Ah with maintenance free sealed lead-acid batteries for SITOP DC UPS module 6 A, 15 A and 40 A

| electrical data | | | |
|--|--|--|--|
| end-of-charge voltage at DC | | | |
| • at -10 °C recommended | 29 V | | |
| • at 0 °C recommended | 28.4 V | | |
| • at 10 °C recommended | 27.8 V | | |
| at 20 °C recommended | 27.3 V | | |
| at 30 °C recommended | 26.8 V | | |
| at 40 °C recommended | 26.6 V | | |
| at 50 °C recommended | 26.3 V | | |
| output | | | |
| battery capacity | 7 A·h | | |
| output current in buffering mode maximum | 30 A | | |
| peak current | 30 A | | |
| charging current maximum | 1.75 A | | |
| output voltage at DC rated value | 24 V | | |
| interfaces | | | |
| communication function | No | | |
| protection and monitoring | | | |
| design of short-circuit protection | Battery fuse 20 A/32 V (solid-state circuitry blade-type fuse + support) | | |
| design of the overload protection | Valve control | | |
| safety | | | |
| operating resource protection class | Class III | | |
| protection class IP | IP00 | | |
| standards, specifications, approvals | | | |
| certificate of suitability | | | |
| • CE marking | Yes | | |
| UL approval | Yes; cURus-Recognized (UL 1778, CSA C22.2 No. 107.1), File E219627 | | |
| EAC approval | Yes | | |
| standards, specifications, approvals hazardous environments | | | |
| certificate of suitability | | | |
| • ATEX | No | | |
| • cCSAus, Class 1, Division 2 | No | | |
| standards, specifications, approvals marine classification | | | |
| shipbuilding approval | Yes | | |
| Marine classification association | | | |
| American Bureau of Shipping Europe Ltd. (ABS) | Yes | | |
| Det Norske Veritas (DNV) | Yes | | |
| standards, specifications, approvals Environmental Product Declaration | | | |
| Environmental Product Declaration | Yes | | |
| Global Warming Potential [CO2 eq] | | | |

| | 27.01 | | |
|---|---|--|--|
| • total | 25.9 kg | | |
| during manufacturing | 12.8 kg | | |
| during operation | 10.7 kg | | |
| after end of life ambient conditions | 0.81 kg | | |
| ambient conditions | | | |
| ambient condition | For storage, mounting and operation of lead-acid batteries, the relevant DIN/VDE regulations or country-specific regulations (e.g. VDE 0510 Part 2/EN 50272-2) must be observed. You must ensure that the battery site is sufficiently ventilated. Possible sources of ignition must be at least 50 cm away. | | |
| ambient temperature | | | |
| during operation | -15 +50 °C | | |
| during transport | -20 +50 °C | | |
| during storage | -20 +50 °C | | |
| relative temporary capacity loss at 20 °C in a month typical | 3 % | | |
| service life of energy storage | | | |
| • typical | capacity falls to 80 % of original capacity (according to EUROBAT) | | |
| at 20 °C typical | 4 a | | |
| ● at 30 °C typical | 2 a | | |
| • at 40 °C typical | 1a | | |
| • at 50 °C typical | 0.5 a | | |
| note | Along with the storage and operating temperature, other factors such as the duration of the storage period and the charge status during storage have a decisive influence on the possible useful life. Batteries should therefore be stored as briefly as possible, always fully charged, and within the temperature range 0 to +20 °C. | | |
| connection method | | | |
| type of electrical connection | spring-loaded terminals | | |
| for power supply unit | 1 screw terminal each for 0.08 4 mm ² for + BAT and - BAT | | |
| mechanical data | | | |
| width × height × depth of the enclosure | 186 × 168 × 121 mm | | |
| installation width × mounting height | 206 × 188 mm | | |
| fastening method | can be screwed onto flat surface (keyhole mounting for hooking in to M4 screws) | | |
| standard rail mounting | No | | |
| S7 rail mounting | No | | |
| wall mounting | Yes | | |
| net weight | 6 kg | | |
| number of cells | 12 | | |
| accessories | | | |
| product component included | Accessories pack with solid-state circuitry fuse 20 A and 30 A | | |
| further information internet links | | | |
| internet link | | | |
| to website: Industry Mall | https://mall.industry.siemens.com | | |
| to web page: selection aid TIA Selection Tool | https://www.siemens.com/tstcloud | | |
| to website: Industrial communication to website: CAy Daymland Manager | http://www.siemens.com/simatic-net | | |
| to website: CAx-Download-Manager to website: Industry Opline Support | http://www.siemens.com/cax | | |
| to website: Industry Online Support additional information | https://support.industry.siemens.com | | |
| other information | Specifications at rated input voltage and ambient temperature +25 °C (unless | | |
| | otherwise specified) | | |
| security information | | | |
| security information | Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase | | |

customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications

| | Version | Classification |
|--------|---------|----------------|
| eClass | 14 | 27-05-04-03 |
| eClass | 12 | 27-05-04-03 |
| eClass | 9.1 | 27-05-04-03 |
| eClass | 9 | 27-05-04-03 |
| eClass | 8 | 27-05-04-03 |
| eClass | 7.1 | 27-05-04-03 |
| eClass | 6 | 27-05-04-90 |
| ETIM | 9 | EC000356 |
| ETIM | 8 | EC000356 |
| ETIM | 7 | EC000356 |
| UNSPSC | 15 | 26-11-17-01 |

Approvals Certificates

General Product Approval

Marine / Shipping



Manufacturer Declaration Declaration of Conformity



Miscellaneous



Marine / Shipping

Dangerous goods

Environment



Dangerous goods information



last modified:

6/25/2024