



- ALL DIMENSIONS ARE IN INCHES[mm]

	<table border="1"> <tr> <th>H1</th> <th>H3</th> <th>H2</th> <th>H4</th> </tr> <tr> <td>190</td> <td>380</td> <td>380</td> <td>416</td> </tr> <tr> <td>199</td> <td>398</td> <td>398</td> <td>416</td> </tr> <tr> <td>208</td> <td>416</td> <td>416</td> <td>416</td> </tr> </table>	H1	H3	H2	H4	190	380	380	416	199	398	398	416	208	416	416	416	<p>252L E50394 PDG12 TYPE E</p>	<p>CONTROL TRANSFORMER P/N C2E1500SP 1500 VA</p>	<p>252L E50394 PDG12 TYPE E</p>	<table border="1"> <tr> <th colspan="2">LV TERMINAL LOCATION</th> </tr> <tr> <td>120</td> <td>240</td> </tr> <tr> <td>115</td> <td>230</td> </tr> <tr> <td>110</td> <td>219</td> </tr> <tr> <td>X4</td> <td>X2 X3 X1</td> </tr> <tr> <td></td> <td>GND</td> </tr> </table>	LV TERMINAL LOCATION		120	240	115	230	110	219	X4	X2 X3 X1		GND	<table border="1"> <tr> <th colspan="2">HV TERMINAL LOCATION</th> </tr> <tr> <td>1</td> <td>2 4</td> </tr> <tr> <td>1</td> <td>3 2 4</td> </tr> </table>	HV TERMINAL LOCATION		1	2 4	1	3 2 4	<p>P/N C2E1500SP 1500 VA 50/60 Hz 130°C CLASS</p>
	H1	H3	H2	H4																																					
190	380	380	416																																						
199	398	398	416																																						
208	416	416	416																																						
LV TERMINAL LOCATION																																									
120	240																																								
115	230																																								
110	219																																								
X4	X2 X3 X1																																								
	GND																																								
HV TERMINAL LOCATION																																									
1	2 4																																								
1	3 2 4																																								
<p>MADE IN MEXICO</p> <p>2066252</p>		<p>LR3902</p>	<table border="1"> <tr> <th>T2</th> <th>T1</th> <th>X4</th> <th>X2</th> <th>X3</th> <th>X1</th> <th>GND</th> </tr> </table>	T2	T1	X4	X2	X3	X1	GND																															
T2	T1	X4	X2	X3	X1	GND																																			

NOTES:



TITLE: 1 PHASE ENCLOSED CONTROL TFX

1	25/09/16	RH	UPDATED EDB	DES: MSARAF
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 1

EDBC2E1500SP