



- FINGER GUARDS FOR TERMINAL BLOCKS AND FUSING OPTIONAL
- OPTIONAL FUSE CLIPS WILL ADD 0.35"[9mm] TO HEIGHT
- OPTIONAL FUSE CLIPS WITH FINGER GUARDS WILL ADD 0.48"[12mm] TO HEIGHT
- OPTIONAL FUSE BLOCK WILL ADD 1.3"[33mm] TO HEIGHT
- OPTIONAL FUSE BLOCK WITH FINGER GUARD WILL ADD 1.5"[38mm] TO HEIGHT
- TOLERANCES STD. +/- 0.1"[+/-3mm]
- ALL DIMENSIONS ARE IN INCHES [mm]

<table border="0"> <tr><td>H1</td><td>H2</td><td>H3</td><td>H4</td></tr> <tr><td>OV</td><td>380</td><td>400</td><td>415</td></tr> <tr><td></td><td>380</td><td>400</td><td>415</td></tr> <tr><td></td><td>380</td><td>400</td><td>415</td></tr> </table>	H1	H2	H3	H4	OV	380	400	415		380	400	415		380	400	415				<table border="0"> <tr><td>H1</td><td>H2</td><td>H3</td><td>H4</td></tr> <tr><td colspan="4">CONTROL TRANSFORMER</td></tr> <tr><td colspan="4">P/N C2G0500MEI</td></tr> <tr><td colspan="4">500 VA</td></tr> <tr><td colspan="4">T2 T1 X3 X2 X1 GND</td></tr> </table>	H1	H2	H3	H4	CONTROL TRANSFORMER				P/N C2G0500MEI				500 VA				T2 T1 X3 X2 X1 GND				 252L E50394 PD012 TYPE 3AH LR3902 TYPE 3AH	 P/N C2G0500MEI 500 VA 50/60 Hz 130°C CLASS	<table border="0"> <tr><td colspan="3">LV TERMINAL LOCATION</td></tr> <tr><td>120</td><td>24</td><td>OV</td></tr> <tr><td>120</td><td>24</td><td></td></tr> <tr><td>120</td><td>24</td><td></td></tr> <tr><td>X3</td><td>X2</td><td>X1</td></tr> <tr><td></td><td></td><td>GND</td></tr> </table>	LV TERMINAL LOCATION			120	24	OV	120	24		120	24		X3	X2	X1			GND
H1	H2	H3	H4																																																										
OV	380	400	415																																																										
	380	400	415																																																										
	380	400	415																																																										
H1	H2	H3	H4																																																										
CONTROL TRANSFORMER																																																													
P/N C2G0500MEI																																																													
500 VA																																																													
T2 T1 X3 X2 X1 GND																																																													
LV TERMINAL LOCATION																																																													
120	24	OV																																																											
120	24																																																												
120	24																																																												
X3	X2	X1																																																											
		GND																																																											

NOTES:



TITLE: 1 PHASE GENERAL PURPOSE CONTROL TFX

			DES: MSARAF
			DATE: 25/06/30
NO.	DATE	BY	REVISION
			SCALE: NTS

SHEET 1 OF 1

EDBC2G0500MEI