



- FINGER GUARDS FOR TERMINAL BLOCKS AND FUSING OPTIONAL
- OPTIONAL FINGER GUARDS WILL ADD 0.1"[3mm] TO HEIGHT
- OPTIONAL FUSE BLOCK WILL ADD 1.3"[33mm] TO HEIGHT
- OPTIONAL FUSE BLOCK WITH FINGER GUARD WILL ADD 1.5"[38mm] TO HEIGHT
- TOLERANCES STD. +/-[+/-3mm]
- ALL DIMENSIONS ARE IN INCHES [mm]

<table border="0"> <tr><td>H1</td><td>H2</td><td>H3</td><td>H4</td></tr> <tr><td>OV</td><td>217</td><td>240</td><td>480</td></tr> <tr><td></td><td>208</td><td>230</td><td>460</td></tr> <tr><td></td><td>199</td><td>220</td><td>440</td></tr> </table> <p>HV TERMINAL LOCATION MADE IN MEXICO SN</p>	H1	H2	H3	H4	OV	217	240	480		208	230	460		199	220	440			<table border="0"> <tr><td>H1</td><td>H2</td><td>H3</td><td>H4</td></tr> </table> <p>CONTROL TRANSFORMER P/N C2M0100MLI 100 VA</p>	H1	H2	H3	H4	<p>LISTED 252L E50394 PDG12 TYPE PH</p>	<p>P/N C2M0100MLI 100 VA 50/60 HZ 130°C CLASS</p>	<table border="0"> <tr><td colspan="3">LV TERMINAL LOCATION</td></tr> <tr><td>120</td><td>25</td><td>OV</td></tr> <tr><td>115</td><td>24</td><td></td></tr> <tr><td>110</td><td>23</td><td></td></tr> <tr><td>X3</td><td>X2</td><td>X1</td></tr> <tr><td></td><td></td><td>GND</td></tr> </table>	LV TERMINAL LOCATION			120	25	OV	115	24		110	23		X3	X2	X1			GND
H1	H2	H3	H4																																									
OV	217	240	480																																									
	208	230	460																																									
	199	220	440																																									
H1	H2	H3	H4																																									
LV TERMINAL LOCATION																																												
120	25	OV																																										
115	24																																											
110	23																																											
X3	X2	X1																																										
		GND																																										

NOTES:



TITLE: 1 PHASE MOLDED CONTROL TFX

1	25/09/16	RH	UPDATED EDB	DES: MSARAF
NO.	DATE	BY	REVISION	SCALE: NTS

SHEET 1 OF 1

EDBC2M0100MLI

THIS DRAWING CONTAINS STRICTLY CONFIDENTIAL INFORMATION BELONGING TO HAMMOND POWER SOLUTIONS AND MUST NOT BE DISTRIBUTED OUTSIDE AUTHORIZED PARTIES.

1.1_jwen 2025/09/22 10:15